



Industrie Service

**Add value,
Inspire trust.**

REPORT OF PERFORMANCE

Manufacturer and client Starkstrom-Gerätebau GmbH
Ohmstrasse 10
D-93055 Regensburg

Object Three-phase cast resin transformer

Type DTTHZ1N 630/20

Serial number 7000394

Examination place Starkstrom-Gerätebau GmbH
Ohmstrasse 10
D-93055 Regensburg

Date: 2018-08-30

Our reference:
IS-EG1-RGB/od

Inspector Dipl.-Ing. (FH) Ordelt

This Document consists of
37 Pages.
Page 1 of 37

Date of tests 26.06. – 27.07.2018

Test program Climatic (C2) and Environmental (E2) tests according to IEC 60076-11 (2004)

Excerpts from this document
may only be reproduced and
used for advertising purposes
with the express written approval
of
TÜV SÜD Industrie Service
GmbH.

Conclusion The three-phase cast resin transformer, DTTHZ1N 630/20, 7000394 passed the C2 and E2 tests.

The test results refer exclusively
to the units under test.

Niederlassung Regensburg
Abteilung Elektro- und Gebäudetechnik
Head of department


Christian Eberle

Inspector


Peter Ordelt

